

# 2020 Consumer Confidence Report for Public Water System CITY OF FLORENCE

This is your water quality report for January 1 to December 31, 2020

For more information regarding this report contact:

CITY OF FLORENCE provides surface water and ground water from **Lake Georgetown and the Trinity Aquifer** located in **Williamson County**.

Name City of Florence Utilities

Phone 254-793-2490

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (254) 793-2490.

## Definitions and Abbreviations

### Definitions and Abbreviations

The following tables contain scientific terms and measures, some of which may require explanation.

Action Level:

The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Action Level Goal (ALG):

The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Avg:

Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Level 1 Assessment:

A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment:

A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL:

The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG:

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL:

The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG:

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

MFL

million fibers per liter (a measure of asbestos)

mrem:

millirems per year (a measure of radiation absorbed by the body)

na:

not applicable.

NTU

nephelometric turbidity units (a measure of turbidity)

pCi/L

picocuries per liter (a measure of radioactivity)

## Definitions and Abbreviations

ppb:	micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
ppm:	milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
ppq	parts per quadrillion, or picograms per liter (pg/L)
ppt	parts per trillion, or nanograms per liter (ng/L)
Treatment Technique or TT:	A required process intended to reduce the level of a contaminant in drinking water.

## Information about your Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

### Information about Source Water

CITY OF FLORENCE purchases water from CITY OF GEORGETOWN. CITY OF GEORGETOWN provides purchase surface water from Lake Georgetown located in Williamson County. Lake Georgetown water source is tested by the City of Georgetown.

## MICROBIOLOGICAL CONTAMINANTS FOR 2020

Constituent	MCL		Highest % of positive samples	Units	Violation (Y or N)	Typical Source of Contamination
Total Organic Carbon	N/A	2.91	N/A	PPM	N	Naturally present in the environment
Turbidity (NTU)	0.3	0.18	N/A	PPM	N	Soil runoff

## INORGANIC CONTAMINANTS

Constituent	MCL	MCLG	Average Level	Range of Detection	Sample Date	Violation (Y or N)	Typical Source of Contamination
Barium (ppm)	2	2	0.0446	0.0386-0.0511	2020	N	Discharge of drilling waste, metal refineries, erosion of natural deposits
Fluoride (ppm)	4	4	0.2	0.2-0.2	2020	N	Erosion of natural deposits; water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Nitrate (ppm)	10	10	1.722	0.2-3.24	2020	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nickel (ppm)	.1	.1	0.0021	.002 – .0021	2020	N	Erosion of natural deposits

## UNREGULATED CONTAMINANTS

Constituent	Average of All Sampling Points	Range of Detected Levels	Sample Date	Typical Source of Contamination
Chloroform (ppb)	8.199	0.0 – 9.0	2020	Unregulated contaminants monitoring helps EPA to determine where certain contaminants occur and whether it needs to regulate those contaminants
Bromoform (ppb)	4.935	0.0 – 7.7	2020	
Bromodichloromethane (ppb)	9.090	0.0 – 15.5	2020	
Dibromochloromethane (ppb)	11.408	1-15.5	2020	

## SYNTHETIC ORGANIC CONTAMINANTS

Constituent	Average of All Sampling Points	Range of Detected Levels	Sample Date	Typical Source of Contamination
Atrazine (ppb)	<0.1	<0.1	2020	Runoff from herbicide used on row crops.

TCEQ completed an assessment of your source water, and results indicate that some of our sources are susceptible to certain contaminants. The sampling requirements for your water system is based on this susceptibility and previous sample data. Any detections of these contaminants will be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system contact **Doug Bryant at 254-793-2490**.

City of Florence ground water test results tested by the City of Florence

## 2020 Water Quality Test Results for City of Florence

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2019	1.3	1.3	0.21	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	2019	0	15	2.2	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Disinfection By-Products	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)	2020	18.9	3 - 28	No goal for the total	60	ppb	N	By-product of drinking water disinfection.

\*\* The value in the Highest Level or Average Detected column is the highest average of all HAA5 sample results collected at a location over a year'

Total Trihalomethanes (TTHM)	2020	72.8	11.6 – 108	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
------------------------------	------	------	------------	-----------------------	----	-----	---	--

\*\* The value in the Highest Level or Average Detected column is the highest average of all TTHM sample results collected at a location over a year'

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	2019	0.0867	0.0867 - 0.0867	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	2019	1.35	1.35 - 1.35	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.

Nickel	2019	0.0011	0.0011-0.0011			ppm	N	Erosion of natural deposits.
Nitrate [measured as Nitrogen]	2020	0.24	0.05 - 0.24	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Selenium	2019	0.0043	0.0043 - 0.0043	50	50	ppb	N	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines.

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Beta/photon emitters	2018	21.8	16 - 21.8	0	50	pCi/L*	N	Decay of natural and man-made deposits.

\*EPA considers 50 pCi/L to be the level of concern for beta particles.

Combined Radium 226/228	2018	2.99	1.29 - 2.99	0	5	pCi/L	N	Erosion of natural deposits.
Gross alpha excluding rad	2018	6.4	5 - 6.4	0	15	pCi/L	N	Erosion of natural deposits.

Volatile Organic Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Xylenes	2018	0.0006	0 - 0.0006	10	10	ppm	N	Discharge from petroleum factories; Discharge from chemical factories.

#### Disinfectant Residual

Disinfectant Residual	Year	Average Level	Range of Levels Detected	MRDL	MRDLG	Unit of Measure	Violation (Y/N)	Source in Drinking Water
Free Chlorine	2020	1.75	0.4 - 5.1	4	4	ppm	N	Water additive used to control microbes.